



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0824

Otsego Northern Catskills BOCES

Project Name: OAOC BOCES

Joshua Reiss
31 Center Street
Oneonta, NY 13820

Project / PO Number: N/A
Received: 10/05/2016 00:00
Reported: 12/15/2016 08:50

Analytical Testing Parameters

Client Sample ID: 114-5
Lab Sample ID: J6J0824-01
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/27/16
Collection Time: 06:27

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0178	0.0150	0.00100	mg/L	G	12/02/16 0800	12/06/16 1724

Analytical Testing Parameters

Client Sample ID: 114-6
Lab Sample ID: J6J0824-02
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/27/16
Collection Time: 06:28

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.00249	0.0150	0.00100	mg/L		12/02/16 0800	12/06/16 1725

Analytical Testing Parameters

Client Sample ID: 110
Lab Sample ID: J6J0824-03
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/27/16
Collection Time: 06:32

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.00532	0.0150	0.00100	mg/L		12/02/16 0800	12/06/16 1725



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0824

Analytical Testing Parameters

Client Sample ID: 109-1
Lab Sample ID: J6J0824-04
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/27/16
Collection Time: 06:28

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.0150, 0.00100, mg/L, 12/02/16 0800, 12/06/16 1726

Analytical Testing Parameters

Client Sample ID: 109-2
Lab Sample ID: J6J0824-05
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/27/16
Collection Time: 06:28

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.0150, 0.00100, mg/L, 12/02/16 0800, 12/06/16 1727

Analytical Testing Parameters

Client Sample ID: 111-1
Lab Sample ID: J6J0824-06
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/27/16
Collection Time: 06:39

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.0150, 0.00100, mg/L, 12/02/16 0800, 12/06/16 1729



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0824

Analytical Testing Parameters

Client Sample ID: 111-2
Lab Sample ID: J6J0824-07
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/27/16
Collection Time: 06:29

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.0150, 0.00100, mg/L, 12/02/16 0800, 12/06/16 1729

Analytical Testing Parameters

Client Sample ID: 201
Lab Sample ID: J6J0824-08
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/27/16
Collection Time: 06:33

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.0150, 0.00100, mg/L, 12/02/16 0800, 12/06/16 1731

Analytical Testing Parameters

Client Sample ID: 304
Lab Sample ID: J6J0824-09
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/27/16
Collection Time: 06:34

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.0150, 0.00100, mg/L, 12/02/16 0800, 12/06/16 1732



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0824

Analytical Testing Parameters

Client Sample ID: 305
Lab Sample ID: J6J0824-10
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/27/16
Collection Time: 06:34

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00186, 0.0150, 0.00100, mg/L, 12/02/16 0800, 12/06/16 1733.

Analytical Testing Parameters

Client Sample ID: 304A
Lab Sample ID: J6J0824-11
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/27/16
Collection Time: 06:34

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.0150, 0.00100, mg/L, 12/02/16 0800, 12/06/16 1733.

Analytical Testing Parameters

Client Sample ID: 310
Lab Sample ID: J6J0824-12
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/27/16
Collection Time: 06:36

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.0150, 0.00100, mg/L, 12/02/16 0800, 12/06/16 1734.



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0824

Analytical Testing Parameters

Client Sample ID: 312
Lab Sample ID: J6J0824-13
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/27/16
Collection Time: 06:37

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.0150, 0.00100, mg/L, 12/02/16 0800, 12/06/16 1735

Analytical Testing Parameters

Client Sample ID: 314A
Lab Sample ID: J6J0824-14
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/27/16
Collection Time: 06:37

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.0150, 0.00100, mg/L, 12/02/16 0800, 12/06/16 1735

Analytical Testing Parameters

Client Sample ID: 316
Lab Sample ID: J6J0824-15
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/27/16
Collection Time: 06:38

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.0150, 0.00100, mg/L, 12/02/16 0800, 12/06/16 1736



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0824

Analytical Testing Parameters

Client Sample ID: 318
Lab Sample ID: J6J0824-16
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/27/16
Collection Time: 06:39

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.0150, 0.00100, mg/L, 12/02/16 0800, 12/06/16 1739

Analytical Testing Parameters

Client Sample ID: 320
Lab Sample ID: J6J0824-17
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/27/16
Collection Time: 06:40

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00588, 0.0150, 0.00100, mg/L, 12/02/16 0800, 12/06/16 1740

Analytical Testing Parameters

Client Sample ID: 202-1
Lab Sample ID: J6J0824-18
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/27/16
Collection Time: 06:41

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.0150, 0.00100, mg/L, 12/02/16 0800, 12/06/16 1741



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0824

Analytical Testing Parameters

Client Sample ID: 202-2
Lab Sample ID: J6J0824-19
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/27/16
Collection Time: 06:42

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.0150, 0.00100, mg/L, 12/02/16 0800, 12/06/16 1741

Analytical Testing Parameters

Client Sample ID: 202-3
Lab Sample ID: J6J0824-20
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/27/16
Collection Time: 06:42

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00189, 0.0150, 0.00100, mg/L, 12/02/16 0800, 12/06/16 1742

Analytical Testing Parameters

Client Sample ID: Green House
Lab Sample ID: J6J0824-21
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/27/16
Collection Time: 06:02

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00199, 0.0150, 0.00100, mg/L, 12/02/16 0800, 12/06/16 1743



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0824

Analytical Testing Parameters

Client Sample ID: Nro Bath
Lab Sample ID: J6J0824-22
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/27/16
Collection Time: 06:05

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00180, 0.0150, 0.00100, mg/L, 12/02/16 0800, 12/06/16 1743

Analytical Testing Parameters

Client Sample ID: Welding Bath
Lab Sample ID: J6J0824-23
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/27/16
Collection Time: 06:07

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.0604, 0.0150, 0.00100, mg/L, G, 12/02/16 0800, 12/06/16 1744

Analytical Testing Parameters

Client Sample ID: Welding Fountain
Lab Sample ID: J6J0824-24
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/27/16
Collection Time: 06:08

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.0150, 0.00100, mg/L, 12/02/16 0800, 12/06/16 1745



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0824

Analytical Testing Parameters

Client Sample ID: Visual Arts
Lab Sample ID: J6J0824-25
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/27/16
Collection Time: 06:10

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00504, 0.0150, 0.00100, mg/L, 12/02/16 0800, 12/06/16 1745

Analytical Testing Parameters

Client Sample ID: 401
Lab Sample ID: J6J0824-26
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/27/16
Collection Time: 06:11

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.0150, 0.00100, mg/L, 12/02/16 0800, 12/06/16 1749

Analytical Testing Parameters

Client Sample ID: 402
Lab Sample ID: J6J0824-27
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/27/16
Collection Time: 06:11

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00169, 0.0150, 0.00100, mg/L, 12/02/16 0800, 12/06/16 1749



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0824

Analytical Testing Parameters

Client Sample ID: 118
Lab Sample ID: J6J0824-28
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/27/16
Collection Time: 06:12

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0109, 0.0150, 0.00100, mg/L, 12/02/16 0800, 12/06/16 1750

Analytical Testing Parameters

Client Sample ID: 128-1
Lab Sample ID: J6J0824-29
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/27/16
Collection Time: 06:13

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00343, 0.0150, 0.00100, mg/L, 12/02/16 0800, 12/06/16 1751

Analytical Testing Parameters

Client Sample ID: 128-2
Lab Sample ID: J6J0824-30
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/27/16
Collection Time: 06:14

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00243, 0.0150, 0.00100, mg/L, 12/02/16 0800, 12/06/16 1751



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0824

Analytical Testing Parameters

Client Sample ID: 134-1
Lab Sample ID: J6J0824-31
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/27/16
Collection Time: 06:18

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00606, 0.0150, 0.00100, mg/L, 12/02/16 0800, 12/06/16 1752

Analytical Testing Parameters

Client Sample ID: 134-3
Lab Sample ID: J6J0824-33
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/27/16
Collection Time: 06:17

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00770, 0.0150, 0.00100, mg/L, 12/02/16 0800, 12/06/16 1753

Analytical Testing Parameters

Client Sample ID: 135
Lab Sample ID: J6J0824-34
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/27/16
Collection Time: 06:21

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00420, 0.0150, 0.00100, mg/L, 12/02/16 0800, 12/06/16 1753



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0824

Analytical Testing Parameters

Client Sample ID: 133
Lab Sample ID: J6J0824-35
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/27/16
Collection Time: 06:19

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0135, 0.0150, 0.00100, mg/L, 12/02/16 0800, 12/06/16 1755

Analytical Testing Parameters

Client Sample ID: CTE Hall Fountain
Lab Sample ID: J6J0824-36
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/27/16
Collection Time: 06:26

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.0150, 0.00100, mg/L, 12/02/16 0800, 12/06/16 1756

Analytical Testing Parameters

Client Sample ID: 114-1
Lab Sample ID: J6J0824-37
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/27/16
Collection Time: 06:23

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00972, 0.0150, 0.00100, mg/L, 12/02/16 0800, 12/06/16 1758



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0824

Analytical Testing Parameters

Client Sample ID: 114-2
Lab Sample ID: J6J0824-38
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/27/16
Collection Time: 06:23

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00491, 0.0150, 0.00100, mg/L, 12/02/16 0800, 12/06/16 1759

Analytical Testing Parameters

Client Sample ID: 114-3
Lab Sample ID: J6J0824-39
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/27/16
Collection Time: 06:24

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00308, 0.0150, 0.00100, mg/L, 12/02/16 0800, 12/06/16 1759

Analytical Testing Parameters

Client Sample ID: 114-4
Lab Sample ID: J6J0824-40
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/27/16
Collection Time: 06:46

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00756, 0.0150, 0.00100, mg/L, 12/02/16 0800, 12/06/16 1800



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0824

Analytical Testing Parameters

Client Sample ID: 218
Lab Sample ID: J6J0824-41
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/27/16
Collection Time: 06:46

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00112, 0.0150, 0.00100, mg/L, 12/02/16 0800, 12/06/16 1801

Analytical Testing Parameters

Client Sample ID: 216
Lab Sample ID: J6J0824-42
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/27/16
Collection Time: 06:46

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.0150, 0.00100, mg/L, 12/02/16 0800, 12/06/16 1801

Analytical Testing Parameters

Client Sample ID: Football Fountain
Lab Sample ID: J6J0824-43
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/27/16
Collection Time: 06:45

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.0150, 0.00100, mg/L, 12/02/16 0800, 12/06/16 1803



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0824

Analytical Testing Parameters

Client Sample ID: 225
Lab Sample ID: J6J0824-44
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/27/16
Collection Time: 06:48

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.00100, 0.0150, 0.00100, mg/L, 12/02/16 0800, 12/06/16 1804

Analytical Testing Parameters

Client Sample ID: 228
Lab Sample ID: J6J0824-45
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/27/16
Collection Time: 06:51

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.00100, 0.0150, 0.00100, mg/L, 12/02/16 0800, 12/06/16 1805

Analytical Testing Parameters

Client Sample ID: 226
Lab Sample ID: J6J0824-46
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/27/16
Collection Time: 06:50

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.00100, 0.0150, 0.00100, mg/L, 12/02/16 0800, 12/06/16 1805



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0824

Analytical Testing Parameters

Client Sample ID: 227
Lab Sample ID: J6J0824-47
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/27/16
Collection Time: 06:50

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.0150, 0.00100, mg/L, 12/02/16 0800, 12/06/16 1807

Analytical Testing Parameters

Client Sample ID: 504
Lab Sample ID: J6J0824-48
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/27/16
Collection Time: 06:55

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00225, 0.0150, 0.00100, mg/L, 12/02/16 0800, 12/06/16 1808

Analytical Testing Parameters

Client Sample ID: 320-2
Lab Sample ID: J6J0824-49
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/27/16
Collection Time: 06:40

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.0150, 0.00100, mg/L, 12/02/16 0800, 12/06/16 1809



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0824

Analytical Testing Parameters

Client Sample ID: Headstart Fountain
Lab Sample ID: J6J0824-50
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/27/16
Collection Time: 06:49

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.0150, 0.00100, mg/L, 12/02/16 0800, 12/06/16 1809

Laboratory

NY: Microbac Laboratories, Inc., New York Division

Definitions

AL: Action Level
RL: Reporting Limit
G: Result fails applicable NYS drinking water standards

Cooler Receipt Log

Cooler ID: Default Cooler Temp: °C

Cooler Inspection Checklist

Checklist table with 4 columns: Item, Yes, No, Yes. Items include Custody Seals Intact and/or No Evidence of Tampering, COC/Labels Agree, Received on Ice (or not required).

Project Requested Certification(s)

Microbac Laboratories, Inc. - Chicagoland
NY Lab ID No: 12006
PA DEP ID: 68-04863

New York State Department of Health
Pennsylvania Department of Environmental Protection

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

Reviewed and Approved By:

Michael Fifield
Division Manager
12/15/2016 08:50

Go Green: Contact Michael Fifield to set up email reporting and invoicing options.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. For any feedback concerning our services, please contact Michael Fifield, Project Manager at michael.fifield@microbac.com. You may also contact Michael Fifield, Managing Director at michael.fifield@microbac.com or Robert Crookston, President at robert.crookston@microbac.com.

Microbac Laboratories, Inc.
CHAIN OF CUSTODY

Samples must be returned on ice

MNY Workorder #

Client Information
 Name: **ONC BOCES**
 Address: 31 Center
 Oneonta, NY 13820
 Contact: **Josh Reiss**
 Phone: _____
 Project: **OAOC BOCES**
 Quote ID: _____
 PO#: _____
 Date Req.: _____


Analysis Requested
 Total Lead (EPA 200.8)
 Receiving Info (Lab Use Only)
 Ice: YES NO
 Cooler: YES NO
 Sample Temp: _____
 Cooler Seal: YES NO
 Pickup: YES NO
 Dropoff: C W
 Accepted? YES NO

Container Material
 Plastic
 Container Size(in MI)
 250 ml
Preservative
 HNO3

Sample Information

1	Description/Location	Date	Time	Matrix		Number of Containers for Analysis Requested	Comments/Field Data
				Type	Type		
1	114-5	9/27/16	6:27	Grab	Grab		
2	114-6	9/27/16	6:28	Grab	Grab		
3	110	9/27/16	6:32	Grab	Grab		
4	109-1	9/27/16	6:28	Grab	Grab		
5	109-2	9/27/16	6:28	Grab	Grab		
6	111-1	9/27/16	6:39	Grab	Grab		
7	111-2	9/27/16	6:29	Grab	Grab		
8	201	9/27/16	6:33	Grab	Grab		
9	304	9/27/16	6:34	Grab	Grab		
10	305	9/27/16	6:34	Grab	Grab		
11	304A	9/27/16	6:34	Grab	Grab		
12	310	9/27/16	6:36	Grab	Grab		
13	312	9/27/16	6:39	Grab	Grab		
14	314A	9/27/16	6:37	Grab	Grab		
15	316	9/27/16	6:38	Grab	Grab		
16	318	9/27/16	6:39	Grab	Grab		
17	320	9/27/16	6:40	Grab	Grab		
18	202-1	9/27/16	6:41	Grab	Grab		
19	202-2	9/27/16	6:42	Grab	Grab		
20	2023	9/27/16	6:42	Grab	Grab		

Print Name and Company
 Sampled: **Josh Reiss - ONC BOCES**
 Received: **Eric Monseu Microbac**
 Received: _____
 Date/Time: 9/27/16
 10:51/6
 Comments



Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are granting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

Microbac Laboratories, Inc.
CHAIN OF CUSTODY

Samples must be returned on ice

MNY Workorder #

Client Information
 Name: **ONC BOCES**
 Address: **31 Center**
Oneonta, NY 13820
 Contact: **Josh Reiss**
 Phone: **OAOC BOCES**
 Project: **PO#:**
 Quote ID: **Date Req.:**

Billing/Invoice:
 ONC BOCES

Receiving Info (Lab Use Only)
 Ice: YES NO
 Cooler: YES NO
 Sample Temp: YES NO
 Cooler Seal: YES NO
 Pickup: YES NO
 Dropoff: C W
 Accepted? YES NO

Container Material
 Plastic
Container Size (in Mi)
 250 ml
Preservative
 HNO3

Analysis Requested
 Total Lead (EPA 200.8)

Sample Information			Matrix	
Description/Location	Date	Time	Type	Number of Containers for Analysis Requested
Green house	9/27/16	6:02	Grab	1
NF Booth	9/27/16	6:05	Grab	
Welding booth	9/27/16	6:07	Grab	
Welding fountain	9/27/16	6:08	Grab	
Visney Arts	9/27/16	6:10	Grab	
401	9/27/16	6:11	Grab	
402	9/27/16	6:11	Grab	
118	9/27/16	6:12	Grab	
128-1	9/27/16	6:13	Grab	
128-2	9/27/16	6:14	Grab	
134-1	9/27/16	6:15	Grab	
134-2	9/27/16	6:15	Grab	
134-3	9/27/16	6:15	Grab	
135	9/27/16	6:17	Grab	
133	9/27/16	6:21	Grab	
CJE Hall fountain	9/27/16	6:19	Grab	
114-1	9/27/16	6:24	Grab	
114-2	9/27/16	6:23	Grab	
114-3	9/27/16	6:23	Grab	
114-4	9/27/16	6:24	Grab	

Comments/Field Data

Comments

Date/Time
 9/27/16
 10:51:00 AM

Print Name and Company
 Josh Reiss - ONC BOCES
 Eric Moxsen Microbac

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are certifying that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

